

- A method to evaluate the probability of saving shortfall for energy performance contracting projects is proposed.
- Two calibrated building energy models are developed using EnergyPlus.
- The influential parameters affecting the chiller plant energy use are identified.
- The probability distributions functions are developed using empirical data.
- A case study is analysed to illustrate the methodology.